



MINIMUM EXCAVATION SIZE:
4'-8" x 7'-8" x DEPTH REQUIRED.

- (A) TRANSFORMER PAD
- (B) LOWER SECTION
- (C) PULLING INSERTS
- (D) 16" X 16" CORNER KNOCKOUTS - VARIOUS SIZES AVAILABLE
- (E) 30" X 48" ACCESS COVER
- (F) UNISTRUT AS REQUIRED
- (G) TRANSFORMER CABLE ACCESS OPENINGS AVAILABLE IN DIFFERENT SIZES.

- ASSEMBLY TO BE PLACED ON A 6" BASE OF CRUSHER RUN FOR EASE OF INSTALLATION AND EVEN LOAD DISTRIBUTION.
- ILLUSTRATION IS TYPICAL ONLY OF GENERAL SERIES CONFIGURATION: FOR SPECIFIC CONFIGURATION, CALL JENSEN PRECAST.

4'-0" x 7'-0"
TRANSFORMER PAD
WITH 3'-0" x 6'-0"
x 3'-6" DEEP VAULT

ORG. DWG. DATE
11-15-00

REV. DWG. DATE



PD4884