



MINIMUM EXCAVATION SIZE:  
5'-6" x 8'-6" x DEPTH REQUIRED.

- (A) TRANSFORMER PAD. WT.= 2,588 Lbs.
- (B) 42" LOWER SECTION. WT.= 6,400 Lbs.
- (C) PULLING INSERTS
- (D) 16" X 16" CORNER KNOCKOUTS - VARIOUS SIZES AVAILABLE
- (E) 30" X 48" ACCESS COVER
- (F) UNISTRUT AS REQUIRED
- (G) TRANSFORMER CABLE ACCESS OPENINGS AVAILABLE IN DIFFERENT SIZES.

■ ASSEMBLY TO BE PLACED ON A 6" BASE OF CRUSHER RUN FOR EASE OF INSTALLATION AND EVEN LOAD DISTRIBUTION.

■ ILLUSTRATION IS TYPICAL ONLY OF GENERAL SERIES CONFIGURATION; FOR SPECIFIC CONFIGURATION, CALL JENSEN PRECAST.

<b>6'-0" x 8'-0"</b> <b>TRANSFORMER PAD</b> <b>WITH 4'-0" x 7'-0"</b> <b>x 3'-6" DEEP VAULT</b>	
ORG. DWG. DATE	REV. DWG. DATE
11-15-00	

**JENSEN**  
PRECAST

**PD7296**