



■ ILLUSTRATION IS TYPICAL ONLY OF GENERAL SERIES CONFIGURATION: FOR SPECIFIC CONFIGURATION, CALL JENSEN PRECAST.

MINIMUM EXCAVATION SIZE:
7'-0" x 12'-6" x DEPTH REQUIRED.

(A) TOP SECTION WT.= 12,300 Lbs.

(B) BOTTOM SECTION WT.= 14,800 Lbs.

(C) 30" DIA. MANHOLE OPENING W/ POLYMER CONCRETE COVER

(D) 5" DIA. TERMINATORS - CAST-IN

(E) SUMP - VARIOUS SIZES AVAILABLE

(F) 61" X 60" TRANSFORMER OPENING

■ DESIGNED FOR NON-TRAFFIC USE.

■ ASSEMBLY TO BE PLACED ON A 6" BASE OF CRUSHER RUN FOR EASE OF INSTALLATION AND EVEN LOAD DISTRIBUTION.

5'-0" x 10'-6" x 7'-0" DEEP PMH TRANSFORMER PAD ENCLOSURE	
ORG. DWG. DATE 11-15-00	REV. DWG. DATE 03-08-05



5106 PMH